

# FCoE Public Data Set 03 – September 2020

## Summary

This data set contains readings from a wide array of instruments and actuators available on the **XCaliber flow Loop** at the **Flow Center of Excellence** in Dordrecht the Netherlands. The data set contains a signature of (simulated) process fouling at XCaliber. This fouling builds up gradually and is flushed out under certain process conditions.

## License

This data set is licensed under the Community Data License Agreement – Permissive, Version 1.0 ([CDLA-Permissive-1.0](#))

## More Information

More information on XCaliber and the Flow Center of Excellence is available at <https://www.flowcenter.nl/en/home-en/>

## Required Citations

Huub Kleinrouweler & Jules Oudmans, FCoE Public Data Set 03 – September 2020, Flow Centre of Excellence & UReason, Dordrecht/Rotterdam, The Netherlands – [www.flowcenter.nl](http://www.flowcenter.nl) and [www.ureason.com](http://www.ureason.com).

## Data Collection & Storage Info

Data was obtained from an OPC factory Server by Schneider Electric using UReason's APM-Studio. Original raw data format, stored by APM-Studio, is available in Microsoft SQL-Server.

## Data Information

Key devices in the data set:

1. ATV\_101 : Frequency Controller (pump drive) for pump 101
2. FT\_100 : Magnetic Induction Flow Transmitter (Main line)
3. FT\_102 : Coriolis Flow Transmitter (mass meter , Main Line)
4. FT\_210 : Magnetic Induction Flow Transmitter (MUT section A)
5. FT\_211 : Magnetic Induction Flow Transmitter (MUT section A)
6. FT\_220 : Magnetic Induction Flow Transmitter (MUT section B)
7. FT\_221 : Magnetic Induction Flow Transmitter (MUT section B)
8. P\_101 : Pump 101
9. PT\_101 : Pressure Transmitter (right after pump section)
10. PT\_201 : Pressure Transmitter (just before pump section)
11. TT\_201 : Temperature Transmitter (just before pump section)

The P&ID (piping and instrumentation diagram) of XCaliber, is provided as part of the data set.

Key features in the data set:

	<b>Device</b>	<b>OPC-item</b>	<b>Description</b>
1.	ATV_101	ATV_101_ATV_ST.PresentValue	Drive RPM - process value
2.	ATV_101	ATV_101_ATV_ST.SetPoint	Drive RPM – setpoint
3.	FT_100	FT_100_Calc_flow	flow (m3/hr; calculated)
4.	FT_100	FT_100_KFact_Value	# puls /hr (KFact = 20000)
5.	FT_102	FT_102_Calc_flow	flow (m3/hr)
6.	FT_210	FT_210_Calc_flow	flow (m3/hr; calculated)
7.	FT_211	FT_211_Calc_flow	flow (m3/hr; calculated)
8.	FT_220	FT_220_Calc_flow	flow (m3/hr; calculated)
9.	FT_221	FT_221_Calc_flow	flow (m3/hr; calculated)
10.	P_101	P_101_Freq_OP	frequency (%) as set by drive
11.	P_101	P_101_Run_CMD	status indicator (pump command running)
12.	P_101	P_101_Running	status indicator (pump running)
13.	P_101	P_101_SDDEVCTL_ST.PV	Motor/PUMP speed RPM
14.	PT_101	PT_101_AINPUT1_ST.PV	process value (barg)
15.	PT_201	PT_201_AINPUT1_ST.PV	process value (barg)
16.	TT_201	TT_201_AINPUT1_ST.PV	process value (o C)

### Data set type

Raw data – multiple conditions.

### Sequence of Events

The system is running with 1 pump ; Frequency SP = 30%, base pressure: 0 barg

1. 16:05:08 start logging
2. 16:07:11 start developing fouling (3 minute steps)
3. 16:25:33 fouling at max
4. 16:28:39 fouling starting to break off (1st part)
5. 16:30:45 start breaking off 2nd part
6. 16:31:39 stop logging